

Er.C.RAJESH KANNA, M.Tech,
Environmental Engineer,
Eastman Consultants,
(Senior Water Treatment Consultant)
E-mail: rajeshbiotech@yahoo.co.in

EASTMAN CONSULTANTS

2678, SOUTHMAIN STREET, THANJAVUR-613009.

01.12.2023

To


Brilliant CBSE School,
No.57B, Sethu Road,
Adhirampattinam,
Pattukkottai.(TK),
Thanjavur District
Pin-614701.

RO permeate sample Report		
SI No	Parameter	Result
1	Colour	1 \geq TCU
2	Taste	A-Agreeable
3	Odour	A-Agreeable
4	pH	7.158
5	TDS	71 mg/L
6	TSS	1 \geq NTU
7	Total Hardness	15.017 mg/L ✓
8	Chloride	26.7 mg/L ✓
9	Calcium	17.34 mg/L ✓
10	Magnesium	11.376 mg/L ✓
11	Mineral Oil	NIL ✓
12	Sulphate	NIL ✓
13	Iron	BDL ✓
14	Pesticide	NIL ✓

Observance:

The analyzed RO permeate sample is found POTABLE.

Truly,


01/12/23